

**TEST REPORT No. 256 SF/24 R**

**Date: 28th of October 2024**

page (pages)

1(2)

**Test methods:** LST EN ISO 22097:2023 Thermal insulation for buildings - Reflective insulation products - Determination of thermal performance.  
LST EN 12667:2002 Thermal performance of building materials and products - Determination of thermal resistance by means of guarded hot plate and heat flow meter methods - Products of high and medium thermal resistance.  
**Test method** – heat flow meter.  
**Type and identification of apparatus** – symmetrical single-specimen apparatus No. 1/99 (ISO 8301).  
(number of normative document or test method, description of test procedure, test uncertainty)

**Customer:** SAS ATI FRANCE, SAS ATI FRANCE, Parc industriel de la Plaine de l'Aine - 1 Avenue des Troussilières- 01150 BLYES, France  
(name and address)

**Manufacturer:** SAS ATI FRANCE, SAS ATI FRANCE, Parc industriel de la Plaine de l'Aine - 1 Avenue des Troussilières- 01150 BLYES, France  
(name and address)

**Samples description:** Type 2 multilayer reflective insulation AIRFLEX, 600×600mm  
(name, description and identification details of a specimen)

**Samples selected:** By customer  
(who selected/place/date)

**Samples delivery date:** 21/10/2024

**Place of samples conditioning:** Building Physics Laboratory, Institute of Architecture and Construction Kaunas University of Technology, Tunelio st. 60, LT 44451 Kaunas, Lithuania  
(name and address)

**Samples conditioning date:** 21/10/2024 – 22/10/2024      **Date of testing:** 22/10/2024 – 23/10/2024

**Production date:** no data

**Tested at:** Building Physics Laboratory IAC KTU  
(name and address)

**Test results:**

| Name of the indicator and unit   | Test method reference no. | Test result |
|--|---------------------------|-------------|
| Declared core thermal resistance of product<br><b>AIRFLEX</b> , $R_{D(core)90/90}$ , (m <sup>2</sup> ·K)/W | LST EN ISO 22097:2023     | <b>0.28</b> |
| Declared thermal resistance of system with 2 air gaps<br>$R_{system 90/90}$ , (m <sup>2</sup> ·K)/W        |                           | <b>1.60</b> |

**Additional information:** Mean ambience temperature 10.00 °C,  
Ambience relative humidity 65.0 %.

**Annexes:** **Annex 1.** Tests results; **Annex 2.** Calculation of declared thermal resistance; **Annex 3.** Calculation of thermal resistance including associated airspaces; **Annex 4.** The parameters of heat flow meter apparatus.

Technical manager:

(approves the test results)



(signature)

J. Ramanauskas

(n., surname)

Tested by:

(technically responsible for testing)

(signature)

A. Burlingis

(n., surname)

Validity – the named data and results refer exclusively to the tested and described specimens.

Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Annex 1. Tests results:**

**Specimen No. 256-1/24**

| <b>Heat flow direction – vertical</b>  |                       |                |
|--|-----------------------|----------------|
| <b>Conditioning of sample – Climate chamber 48 h, T = 23±2°C, RH = 50±5 %.</b> |                       |                |
| <b>Testing parameters</b>  | <b>unit</b>           | <b>Value</b>   |
| Temperature of hot plate, $T(h)$   | °C                    | 20.02          |
| Temperature of cold plate, $T(c)$  | °C                    | 0.02           |
| Density of heat flow of hot plate, $q(h)$                                      | W/m <sup>2</sup>      | 32.51          |
| Density of heat flow of cold plate, $q(c)$                                     | W/m <sup>2</sup>      | 32.24          |
| Mean density of heat flow through the specimen, $q$                            | W/m <sup>2</sup>      | 32.37          |
| Mean temperature of specimen, $T$  | °C                    | 10.02          |
| Mean thermal conductivity, $\lambda$   | W/(m·K)               | <b>0.03912</b> |
| Uncertainty of the measurement, $\Delta\lambda$                                | W/(m·K)               | ± 0.000172     |
| Core thermal resistance, $R_c$   | (m <sup>2</sup> ·K)/W | <b>0.61781</b> |
| Uncertainty of the measurement, $\Delta R$                                     | m <sup>2</sup> ·K/W   | ± 0.0022       |

**Specimen No. 256-2/24**

| <b>Heat flow direction – vertical</b>  |                       |                |
|--|-----------------------|----------------|
| <b>Conditioning of sample – Climate chamber 48 h, T = 23±2°C, RH = 50±5 %.</b> |                       |                |
| <b>Testing parameters</b>  | <b>unit</b>           | <b>Value</b>   |
| Temperature of hot plate, $T(h)$   | °C                    | 20.02          |
| Temperature of cold plate, $T(c)$  | °C                    | 0.01           |
| Density of heat flow of hot plate, $q(h)$                                      | W/m <sup>2</sup>      | 34.00          |
| Density of heat flow of cold plate, $q(c)$                                     | W/m <sup>2</sup>      | 32.43          |
| Mean density of heat flow through the specimen, $q$                            | W/m <sup>2</sup>      | 32.21          |
| Mean temperature of specimen, $T$  | °C                    | 10.02          |
| Mean thermal conductivity, $\lambda$   | W/(m·K)               | <b>0.04004</b> |
| Uncertainty of the measurement, $\Delta\lambda$                                | W/(m·K)               | ± 0.000173     |
| Core thermal resistance, $R_c$   | (m <sup>2</sup> ·K)/W | <b>0.6025</b>  |
| Uncertainty of the measurement, $\Delta R$                                     | m <sup>2</sup> ·K/W   | ± 0.0021       |

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Specimen No. 256-3/24**

| <b>Heat flow direction – vertical</b>  |                       |                |
|--|-----------------------|----------------|
| <b>Conditioning of sample – Climate chamber 48 h, T = 23±2°C, RH = 50±5 %.</b> |                       |                |
| <b>Testing parameters</b>  | <b>unit</b>           | <b>Value</b>   |
| Temperature of hot plate, $T(h)$   | °C                    | 20.02          |
| Temperature of cold plate, $T(c)$  | °C                    | 0.01           |
| Density of heat flow of hot plate, $q(h)$                                      | W/m <sup>2</sup>      | 35.76          |
| Density of heat flow of cold plate, $q(c)$                                     | W/m <sup>2</sup>      | 32.48          |
| Mean density of heat flow through the specimen, $q$                            | W/m <sup>2</sup>      | 34.12          |
| Mean temperature of specimen, $T$  | °C                    | 10.01          |
| Mean thermal conductivity, $\lambda$   | W/(m·K)               | <b>0.03938</b> |
| Uncertainty of the measurement, $\Delta\lambda$                                | W/(m·K)               | ± 0.000170     |
| Core thermal resistance, $R_c$   | (m <sup>2</sup> ·K)/W | <b>0.5861</b>  |
| Uncertainty of the measurement, $\Delta R$                                     | m <sup>2</sup> ·K/W   | ± 0.0020       |

**Specimen No. 256-4/24**

| <b>Heat flow direction – vertical</b>  |                       |                |
|--|-----------------------|----------------|
| <b>Conditioning of sample – Climate chamber 48 h, T = 23±2°C, RH = 50±5 %.</b> |                       |                |
| <b>Testing parameters</b>  | <b>unit</b>           | <b>Value</b>   |
| Temperature of hot plate, $T(h)$   | °C                    | 20.02          |
| Temperature of cold plate, $T(c)$  | °C                    | 0.02           |
| Density of heat flow of hot plate, $q(h)$                                      | W/m <sup>2</sup>      | 34.50          |
| Density of heat flow of cold plate, $q(c)$                                     | W/m <sup>2</sup>      | 32.12          |
| Mean density of heat flow through the specimen, $q$                            | W/m <sup>2</sup>      | 33.31          |
| Mean temperature of specimen, $T$  | °C                    | 10.02          |
| Mean thermal conductivity, $\lambda$   | W/(m·K)               | <b>0.03812</b> |
| Uncertainty of the measurement, $\Delta\lambda$                                | W/(m·K)               | ± 0.000168     |
| Core thermal resistance, $R_c$   | (m <sup>2</sup> ·K)/W | <b>0.6004</b>  |
| Uncertainty of the measurement, $\Delta R$                                     | m <sup>2</sup> ·K/W   | ± 0.0021       |

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Annex 2. Calculation of declared thermal resistance**

| Sample No.      | Core thermal resistance of double sample, $R_c$ | Effective thermal conductivity, $\lambda$ | Thickness of double sample, mm |
|-----------------|---|---|--------------------------------|
| 1               | 0.617808  | 0.391222                                  | 24.17                          |
| 2               | 0.602462  | 0.0400357                                 | 24.12                          |
| 3               | 0.586127  | 0.0393771                                 | 23.08                          |
| 4               | 0.600431  | 0.0381226                                 | 22.89                          |
| <i>Average:</i> | <i>0.601707</i>                                 | <i>0.0391644</i>                          | <i>23.57</i>                   |

Sample size: 600 x 600 mm.

**Declared derived R-value of double insulation product:**

$$S_{R(\text{core})} = \sqrt{\frac{\sum (R_i - R_{\text{average}})^2}{n - 1}};$$

$$S_{R(\text{core})} = 0.01123;$$

$$R_{D(\text{core})90/90} = R_{\text{average}} - k_2 \cdot S_{R(\text{core})};$$

$$k_2 = 3.19$$

$$R_{D(\text{core})90/90} = 0.56589 = 0.56 \text{ m}^2 \cdot \text{K/W}$$

**Declared thermal resistance of the core  $R_{D(\text{core})}$  of one insulation product**

$$R_{D(\text{core})90/90} = 0.56589/2 = 0.282945 = 0.28 \text{ m}^2 \cdot \text{K/W}$$

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Annex 3. Calculation of thermal resistance including associated airspaces according EN 16863 Annex D and EN ISO 6946:**

- Declared emissivity of the product surfaces 0.05;
- Temperature difference across each air cavity of 5K, mean temperature of 10°C;
- Thermal resistance of one air gaps 0.6640 m<sup>2</sup>·K/W;
- Thermal resistance of two air gaps 1.3280 m<sup>2</sup>·K/W;

**Calculation of thermal resistance including two vertical airspaces:**


Air gap 20 mm – Product - Air gap 20 mm

$$R_{D(system) 90/90} = 0.282945 + 1.3280 = 1.610945 = 1.60 \text{ m}^2 \cdot \text{K/W}$$

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Annex 4. The parameters of heat flow meter apparatus:**

SCHEME OF HEAT FLOW METER APPARATUS  
Single specimen symmetrical configuration apparatus



- |                                       |   |
|---------------------------------------|---|
| 1 – Specimen under testing;           | 7 – Heat flow meter at cooling plate;     |
| 2 – Cooling plate;                    | 8 – Thermo-couple;                        |
| 3 – Heating plate;                    | 9 – Guarded space,                        |
| 4 – Cooling thermostat;               | 10 – Surrounding with controlled constant |
| 5 – Heating thermostat;               | temperature.                              |
| 6 – Heat flow meter at heating plate; |   |

**Notes:**

- Specimen dimensions 600 x 600 mm, central measuring area of heat flow meter 250 x 250 mm.
- Possibility to measure under various heat flow directions: horizontal, upwards, downwards, on different angles with horizontal plane.
- Used edge heat losses reduction methods:
  - Specimen thickness limitation (to 150 mm);
  - Controlled ambient temperature during the test equal to the mean specimen temperature.

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.